

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Saudi Ceramic Company

PO Box 3893, Riyadh, Saudi Arabia

For the following product(s):

Ceramic/Porcelain Flooring:

Floor Tiles Gp BIIa WA >3 up to 6%, Gp BIIb WA >6 up to 10% and Group BIII WA greater than 10%, Porcelain Tile Group BIa WA max 0.5%, Gp BIb WA >0.5% up to 3%

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-03618

Valid from: July 1, 2020 to June 30, 2021

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ISO/IEC 17065
Product Certification Body
#0821

A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA

