

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Tarkett

30000 Aurora Road, Solon, OH, United States

For the following product(s):

Wall Base and Stair Treads:

BaseWorks, Finishing Accessories, Leveler Strips, Millwork, Nosings, Perceptions Collection, rePlace Wall Base, Residential Vinyl Wall Base, Rubber Stair Treads, TightLock, Traditional Collections, Vent Cove Base, Vinyl Cove Base, Vinyl Moldings, Vinyl Stair Treads, Wall Art Decorative Wall Base

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters^{1,2}

¹Modeled Product Type: 10 in Wall Base (School Classroom)

²Modeled Product Type: 4 in Wall Base (Private Office)

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-02078

Valid from: July 1, 2018 to June 30, 2019

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI Accredited Program
Product Certification
#0821



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA